

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200860
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------|----------------|----------|----------------------------|
| DE - Street - Base Lift | Ronald Paynter | Passed | Thursday, June 18, 2020 |

Informational:
1 Misc Jeff's crew from Hanrahan Asphalt laid 355 tons of Type 01-01 base asphalt 3 1/2 inches thick for the parking lot. Matt from Terracon was also present taking density readings. RP 6-18-20

Comments: