

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193328  
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Site Visit</b>	Joe Starlin	Partial	Thursday, June 18, 2020

Informational:  
1 Misc 6-18-20 2:40pm I met with Brad Wehde to look at his sidewalk on the west side of the site. I will need to talk to Steve Robbins on how to proceed. They did not install ADA domes and the walk is holding water.

**Comments:**