CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191010

Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Friday, June 19, 2020

Residential

Corrective Action Required:

1 Misc - Furnace to be properly hardwired

- Water heater discharge pipe shall terminate not more than 6" and not less

than two times the discharge pipe diameter size above the floor

- Correct broken hold down clamps for main service line above electric

service panel

- Install dishwasher to complete kitchen plumbing

- Seal all exterior penetrations in siding

Comments: