

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20190683
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064
Inspected On: Friday, June 19, 2020
Inspected By: Khanh Nguyen
Expiration Date: 7/20/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, June 19, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -Approval required from: Field Service, Planning, Fire, and Water
-Expose light pole grounding connection and raceway; Ground all light poles; verify raceway buried depth per code (min 24" under parking lot, 18" everywhere else)
-Vent bath fan of NW classroom to outside
-Label AC units
-Install tamper-proof receptacles throughout the childcare facility as required per NEC 406.12
-Adjust all doors opening force to 5lbs or less
-Receptacles located within six ft of the sinks must be gfci-protected (microwave, refrigerator, tv, etc)
-Protect exposed plumbing under kitchen sinks
-All single phase receptacles rated 50 amperes or less located in the |
|---|------|---|

kitchen must be gfci-protected. NEC 210.8(B)

- Install receptacle cover plate inside closet of SE classroom

- Support receptacle yoke at sink in room with access to mezzanine

- Complete gas supply to furnace; complete insulating fresh air ducting