

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193184
Address: 1409 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, June 19, 2020

Corrective Action Required:

1	Misc	- Strap top plate at DWV in pantry - Remove lid at front porch to allow inspection of all truss hangers - cannot inspect all truss hangers currently - EC#2 800 lb hold down per plans
---	------	--

Comments: