

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, June 19, 2020

Corrective Action Required:

1	Misc	-3RD FLOOR LEFT WING-
		-SIGNAGE THROUGHOUT
		-SEAL PENETRATIONS IN ELEVATOR EQUIPMENT ROOM
		-322 LOOSE OUTLET IN BATHROOM
		-329 FAULTY GFCI BY FRIDGE
		-330 BATH FAN NOT FUNCTIONING IN 2ND BATH
		-331 TIGHTEN MIDDLE POST ON PATIO RAILING
		-333 BATH FAN NOT FUNCTIONING

Comments: