

Inspection Summary

Permit #: PRSUBD20200801,

CHAPEL RIDGE BUSINESS PARK - LOTS 9BB, 9C, & 9D

Address: 3130 NE CARNEGIE DR, LEES SUMMIT, MO 64064
3131 NE CARNEGIE DR, LEES SUMMIT, MO 64064
640643100 NE CARNEGIE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI - Sanitary Sewer - Camera Test Informational 1	Steve Robbins	Passed	Friday, June 19, 2020
Corrective Action Required 2	They had to put grout around the pipes going into the MH. They have completed the job.		

Comments: