

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193623
Address: 440 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Monday, June 22, 2020

Corrective Action Required:

1	Misc	PENDING HEALTH DEPT. APPROVAL
---	------	-------------------------------

Backflow preventer clarification pending on the RPZ-
needs to meet ASSE 1022

Comments: