

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192662  
Address: 2909 NW AUDUBON LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Tuesday, June 23, 2020

Corrective Action Required:

1	Misc	- ADDRESS FAILED SEWER SERVICE INSPECTION - - PROVIDE SOD, SPLASH BLOCKS - - PROVIDE HAMMER ARRESTOR AT DISHWASHER - - TIGHTEN HANDRAIL BRACKETS -
---	------	---

**Comments:**