

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192156  
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Mark Harding	Partial	Tuesday, June 23, 2020

Informational:	
1 Misc	6 sections 1st layer wrap 4' from flange welds approved on all 6 sections
Informational:	
2 Misc	WELDS APPROVED HOOD DUCTS #4 #5 #6 ( 2 PCS )
	VERTICAL GROUND WELDS HOODS 1,2,3,-OK

**Comments:**