



### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20201168	Date:	June 23, 2020
Project Title:	PICKUP USA FITNESS	Applicant:	
Location:	2724 NE MCBAIN DR, LEES SUMMIT, MO 64064		
Type of Work:			ELECTRONIC CONTRACTING COMPANY
Occupancy Group:	F-2		6501 NORTH 70TH ST
Description:	TENANT FINISH FOR BASKETBALL		LINCOLN, NE 68504
THEMED GYM		Primary:	(402) 466-8274 Ext: MAILING
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**