



June 22, 2020

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue correction for plumbing holes in floor joists for Lot # 69 Hawthorne Ridge – 2923 SW Arborwood Dr. Lee's Summit, MO 64082 – Permit # PRRES20200067

This letter addresses the correction for the field issue of plumbing holes cut into floor joists for bathroom #2 above the great room/dining area.

The revision shall be as follows:

- Remove section of plumbing running through affected floor joists.
- Sister #2 2x10 to existing floor joist with one end support on exterior wall and a minimum of 6' attached to existing joist measured from centerline of hole.
- Attach existing joist to sistered joist with glue and 16D nails, 4 nails per linear foot in a "W" pattern.
- New holes shall not be within top or bottom 2" of sistered floor joist.

Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

