

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191010
Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, June 23, 2020

Corrective Action Required:

1	Misc	Contact Mark Harding -MARK HARDING 06/23/2020 1:05 PM, personal items and occupied without approval. - Furnace to be properly hardwired - Water heater discharge pipe shall terminate not more than 6" and not less than two times the discharge pipe diameter size above the floor - Correct broken hold down clamps for main service line above electric service panel - Install dishwasher to complete kitchen plumbing - Seal all exterior penetrations in siding
---	------	--

Comments: