

# Inspection Summary

Permit #: PRCOM20191159, Building Permit - Commercial  
SUMMIT WAVES - WAVE POOL  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

## Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Field Services	Steve Robbins	Temporary C of O	Tuesday, June 23, 2020

## Corrective Action Required

1. Wating on as-builds for the detention basin. 2. Grading needs to be finished. 3. 70% vegetation needs to be established throughout the entire site. (this is being performed by Parks and Rec. 4. The end section needs to be installed that goes out onto Jefferson. 5. Drain lid needs to be replaced on the north side of the building. 6. The construction entrance needs to be removed and graded properly so seed can be installed.

Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Tuesday, June 23, 2020
-----------------------------------------	--------------	------------------	------------------------

## Corrective Action Required

1. OK to TCO-2 weeks for electrical issue. Please contact Mark Harding when complete.  
\* Provide GFCI protection on Food truck 50 amp circuit east side of wave pool at pedestal. Breaker to be removed or shut down at main panel in pool equipment room until circuit is GFCI protected.  
Provide approval from other City Divisions on separate letter.

## Comments: