CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

| Permit #: | PRRES20192994 | | |
|------------------|--|--|--|
| Address: | 4401 SW TANZANITE CIR, LEES SUMMIT, MO 64082 | | |
| Inspected On: | Wednesday, June 24, 2020 | | |
| Inspected By: | Patrick Schonfeldt | | |
| Expiration Date: | 7/8/2020 12:00:00 AM | | |

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|------------------|-----------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Temporary C of O | Wednesday, June 24, 2020 |

Corrective Action Required:

1 Misc

- Submit as graded plot plan for review

- Obtain lawn irrigation system permit

- Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"

2 WEEK TCO, SUBMIT AS GRADED PLOT PLAN