

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200067  
Address: 2923 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Wednesday, June 24, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Address joists bored for DWV above living room, cannot be bored closer than 2" to top and bottom of joist - complete DWV based upon engineer letter</li><li>- Truss hangers per plans - garage , unable to check 2nd floor, truss layout for 2nd floor not in packet</li><li>- Truss bracing per plan - unable to check 2nd floor, truss layout missing for 2nd floor</li><li>- Support and protect pex at showers</li><li>- EC#2 hold down per plan 2nd floor - master bed, bed #2, stairway above entry</li></ul>
---	------	---

**Comments:**