

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200267  
Address: 133 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, June 24, 2020

Informational:	
1 Misc	PFH GARAGE PORTAL FRAMING HOLD DOWNS, NAILING PATTERN, HEADER TO JACK STUD STRAPS, 5/8 ANCHOR BOLTS OK TO COVER -
Corrective Action Required:	
2 Misc	<ul style="list-style-type: none"><li>- PROVIDE BP 1 BLOCKING PER JOIST LAYOUT BASEMENT -</li><li>- PROVIDE (5) 2 X 6 EACH END STEEL BEAM GARAGE PER PLAN -</li><li>- FIRE BLOCKING ENTRY CLOSET/ FT DOOR -</li><li>- TIGHTEN ANCHOR BOLTS GARAGE -</li><li>- PROVIDE ANCHOR BOLT GARAGE NEAR ENTRY CLOSET-</li><li>- PROVIDE STRAP VENT @ TOP PLATE BED #4 -</li><li>- INSTALL FIREPLACE @ PATIO ( FRAMING, ELEC &amp; GAS ) -</li><li>- SECURE GAS LINE AT SLIDING GLASS DOOR -</li></ul>

**Comments:**