

June 23, 2020



City of Lee's Summit
220 SE Green Street
Lee's Summit, Missouri 64063

Attn: Building Inspections
Re: McFarland Custom Homes, Eagle Creek, Lot 671, 2521 NW River Trail Road,
Lee's Summit, Missouri, Permit No. 2020-0905; garage slab inspection

To whom it may concern:

An inspection was conducted on Tuesday, June 23, 2020 regarding the above referenced. For reference purposes, the house faces west. The No. 4 rebar reinforcing steel for this location was installed 12" o.c.b.w. throughout the structural garage slab. The 2 matts of ½" rebars on 6" centers both ways were in place over each garage column. Permission was given to MD Concrete to place the concrete into the garage slab forms. If you have any questions, please contact me at my office.

Sincerely,
Logan & Associates, Inc.

Charles R. Logan, P.E.
President



cc: McFarland Custom Homes