## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500

NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

DE - Stabilized Subgrade Ronald Paynter Partial Wednesday, June 24, 2020

Informational:

1 Misc

Brian tilled in 5% Portland cement, 6 inches deep. KC Testing was out here monitoring and taking test samples. Tentative plan for proof rolling is next

Monday afternoon. RP 6-3-20

Informational:

2 Misc Spalding has started laying and rolling the rock base. RP 6-11-20

Informational:

3 Misc Spalding has got all the rock down and rolled / graded in. Just need to let in

set up and bake now. RP 6-12-20

Informational:

4 Misc Brian's crew tilled in 5% Portland concrete 6 inches deep on the center

section of Woodside Ridge (O'Brien, Ambersham and Killarney). KC Testing

was on site to check compaction. They hit the AT&T line crossing

Ambersham. AT&T is digging an trench across the roadway to splice in the

new line. RP 6-24-20

## **Comments:**