

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192861  
Address: 2919 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                   |
|-------------------------------------------------|--------------------|----------|-------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Thursday, June 25, 2020 |

Corrective Action Required:

|   |      |                                                                                                                                                    |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | - Complete final grade and sod<br>- Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36" |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**