CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20193399

Address: 1516 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

Inspected On: Thursday, June 25, 2020

Inspected By: Patrick Schonfeldt

Expiration Date: 7/9/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Patrick Schonfeldt Temporary C of O Thursday, June 25,

Codes Residential 2020

Corrective Action Required:

Misc - Seal around all exterior light fixtures

- Obtain lawn irrigation system permit

- Place splashblocks at all downspout and sump pump discharge

locations for minimum distance from foundation 36"

- Complete final grade and sod

OK for TCO