

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Backflow Preventer and Vault</b>	Ronald Paynter	Partial	Thursday, June 25, 2020

Corrective Action Required:

1	Misc	Fire line back flow vault is missing its required floor and drain per detail #5 on page C7.2 per the plans. RP 5-13-20
---	------	--

Informational:

2	Misc	Forms were placed and aggregate was present. Steel rebar was placed on 6 inch centers throughout the floor and drain. RP 6-25-20
---	------	--

**Comments:**