

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200178
Address: 207 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Thursday, June 25, 2020

Corrective Action Required:

1	Misc	--install plumbing protection plates at stud walls. --change PVC to case above ceiling. covered without approval. Contractor said he was told to take pictures and sheetrock the wall. I call the contract Scott and no answer.MARK HARDING 06/25/2020 12:20 PM
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: