

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200716  
Address: 910 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, June 25, 2020

Corrective Action Required:

1	Misc	-ISOLATE THE EQUIPMENT GROUNDING CONDUCTORS (EGC) FROM THE GROUNDED CONDUCTORS. INSTALL GROUNDING BUSBAR FOR CONNECTIONS OF MULTIPLE EGC
---	------	--

**Comments:**