

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200717
Address: 910 NW BLUE PKWY, Unit:U, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Failed	Thursday, June 25, 2020

Corrective Action Required:

1	Misc	-ISOLATE THE EQUIPMENT GROUNDING CONDUCTORS (EGC) FROM THE GROUNDED CONDUCTORS. INSTALL GROUNDING BUSBAR FOR CONNECTIONS OF MULTIPLE EGC
---	------	------------------------------------------------------------------------------------------------------------------------------------------

Comments: