

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20201154	Date:	June 26, 2020
Project Title:	SHINING LIGHT MUSIC - STUDIOS	Applicant:	
Location:			
616 SW 3RD ST, LEES SUMMIT, MO 64063		AMERICAN FIRE SPRINKLER CORPORATION	
Type of Work:		PO BOX 958	
Occupancy Group:	MIX	MISSION , KS 66201	
Description:	TENANT FINISH FOR MUSIC		
TEACHING STUDIOS		Primary: (913) 722-6900	
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a Hydrostatic Test.

2. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

(Informational Purposes)

Maintain operation of existing sprinkler system during the addition.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.