

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200445
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Passed	Friday, June 26, 2020

Informational:
1 Misc

UNDERSLAB PLUMBING OK BELOW:
-SANITARY DRAINAGE COMPLETED
-GREASE WASTE DRAINAGE AND INTERCEPTOR
-STORM DRAIN

Comments: