

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200275  
Address: 4400 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:         | Outcome: | Date:                 |
|---|--------------------|----------|-----------------------|
| <b>Gas Service Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Friday, June 26, 2020 |

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | - Gas pressure at 0 psi -<br>- Gas pressure must hold at 10 psi for 15 minutes minimum |
|---|------|--|

**Comments:**