

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193058  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Michael Harkins	Partial	Monday, June 29, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- (6) 3" CONDUITS GENERATOR TO BLDG "E" - - (2 )4" CONDUITS BUILDING "F"TO TRENCH FOR ABOVE -
---	----------------------------------	--

**Comments:**