

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193536
Address: 1410 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, June 29, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Staple plans- Fireblock at HVAC, DWV fur outs in garage- Protect and support pex at showers- Fireblock HVAC DWV chase living room- Truss hangers per plans- Truss bracing per plans- No truss layout found for 2nd floor - unable to inspect 2nd floor- Complete and terminate NM master water closet |
|---|------|--|

Comments: