

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200267  
Address: 133 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Monday, June 29, 2020

Informational:	
1 Misc	PFH GARAGE PORTAL FRAMING HOLD DOWNS, NAILING PATTERN, HEADER TO JACK STUD STRAPS, 5/8 ANCHOR BOLTS OK TO COVER -
Corrective Action Required:	
2 Misc	- INSTALL FIREPLACE @ PATIO ( FRAMING, ELEC & GAS ) - - PROVIDE MIN 10 PSI FOR GAS SERVICE INSPECTION -

**Comments:**