

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20201133

Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Failed	Monday, June 29, 2020

Corrective Action Required:

1	Misc	no inspections until Electrical contractor is verified. Porter Elect - is not the electrical contractor.
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	-SEAL HOLES IN EXISTING DEMISING WALL -MISSING WIRE CLIPS AND RECEPTACLE BOXES -MOVE JUNCTION BOXES TO BE OUTSIDE OF WALLS AND ACCESSIBLE AFTER FINISH
---	-----------------------------	---

**Comments:**