

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191837

Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Flush	Steve Robbins	Passed	Tuesday, April 28, 2020

Informational:

1 Misc

The contractor flushed the fire line after the tie in as we were flushing the main. The fire line and water main was flushed for approximately 25 minutes.

Comments: