CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20193318Address:4400 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|-----------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Monday, June 29, 2020 |

| Corrective | Action | Required | |
|------------|--------|-----------|--|
| CONECTIVE | ACTION | nequireu. | |

| 1 | Misc | - Submit as graded plot plan for review |
|---|-----------------------------------|---|
| | | - Obtain lawn irrigation system permit |
| | | - Complete final grade and sod |
| | | - Seal around all exterior light fixtures |
| | - Seal all penetrations in siding | |
| | | - Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36" |
| | | Security screws at garage door, provide (2) 3" screws each exterior hinge and strike plate |
| | | - Breaker lockouts for hardwired appliances in kitchen - cannot check due to note saying sealant on concrete still drying not to walk on basement floor |

Comments: