

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20201058
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer Construction Inspection	John Jackson	Partial	Monday, June 29, 2020

Informational:
1 Misc Contractor completed the Tie -in on the main sewer line with a 8"x4" wye & installed 4" service line as-per plan see C6.0 (ss-1,ss-2, & ss-3). 6/29/20 Monday

Comments: