

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201133

Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Tuesday, June 30, 2020

Corrective Action Required:

2	Miscellaneous Correction	-MISSING WIRE CLIPS AT RECEPTACLE BOXES -MOVE JUNCTION BOXES OR ADD MUD RINGS TO BE OUTSIDE OF WALLS AND ACCESSIBLE AFTER FINISH -ALL WOOD BLOCKING TO BE FIRE TREATED -ALL WALL TYPE 1 TO BE FULL HEIGHT AND HAVE HORIZONTAL STUDS EVERY 16"
---	-----------------------------	---

Comments: