

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183647
Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line Construction Inspection	John Jackson	Partial	Tuesday, June 30, 2020

Informational:	
1 Misc	Contractor installed Siamese twin 6" fire protection water mains. Approximately 100' feet for both lines. 2/90 deg bend on both fire protection lines.

Comments: