

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192831  
Address: 2916 NW AUDUBON LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Partial	Tuesday, June 30, 2020

Corrective Action Required:

1	Misc	Finished driveway approach meets LS and ADA specs. 2 panels of of curbing for the driveway are busted and needs to be replaced. RP 6-5-20
---	------	---

Informational:

2	Misc	Busted curbing has been removed properly. Forms and rebar has been placed. RP 6-30-20
---	------	---

**Comments:**