

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200246  
Address: 208 NW CARSON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                        | Inspector:      | Outcome: | Date:                  |
|----------------------------------------------------|-----------------|----------|------------------------|
| <b>Electrical Service Inspection - Residential</b> | Michael Harkins | Failed   | Tuesday, June 30, 2020 |

Corrective Action Required:

|   |      |                                                                                |
|---|------|--------------------------------------------------------------------------------|
| 1 | Misc | - REMOVE GREEN BONDING SCREW @ SUBPANEL -<br>( OR PROVIDE MANUFACTURES SPECS ) |
|---|------|--------------------------------------------------------------------------------|

**Comments:**