

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200246
Address: 208 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, June 30, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- ADDRESS RAFTERS LANDING ON BLOCKS -- SEAL ALL UPWARD & EXTERIOR PENETRATIONS -- FIRE BLOCK BASEMENT FURR OUT VERTICAL EVERY 10' & VERTICAL TO HORIZONTAL -- TIGHTEN ANCHOR BOLTS THROUGHOUT -- PROVIDE ANCHOR BOLTS WITHIN 12" OF PLATE BRACKS THROUGHOUT -- ALL ANCHOR BOLTS SHALL BE LOCATED IN MIDDLE THIRD OF THE WIDTH OF PLATE (R403.1.6) -- PROVIDE SOLID SECURITY BLOCKING SIDE GARAGE DOOR -- FIRE BLOCK CHASE NEAR PANTRY -- NAIL JOIST HANGERS ABOVE BASEMENT LANDING -- FOUNDATION PLAN SHOWS W10X22 BEAM AT MEDIA/STORAGE ROOM --- 3RD PARTY SUSPENDED SLAB INSPECTION ABOVE SAFE ? -- LIST SUBJECT TO CHANGE UPON REVIEW OF CITY STAMPED PLANS & FIRE BLOCKING COMPLETION) -
---	------	---

Comments: