



June 26, 2020

Summit Homes  
120 SE 30<sup>th</sup> St  
Lee's Summit, MO 64082

**RE: Subgrade Inspection for Lot # 15 Hawthorne Ridge – 3000 SW Arboridge Dr  
Lee's Summit, MO 64082 – Permit # PRRES20201532**

On June 25, 2020, a special inspection was performed by Residential Engineering Services, LLC (R.E.S.) at the above referenced property. The purpose of this inspection was to verify competent subgrade soils, for follow on footings.

- RES verified that the subgrade soils are a competent clay soil with no apparent compaction or moisture issues.

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

Bradley Huxol, PE

