



June 30, 2020

Robb Popp  
City of Lee's Summit Inspector  
220 SE Green  
Lee's Summit, MO 64063

Re: Fresh Green – Lee's Summit  
1041 NE Sam Walton Dr.  
Lee's Summit, MO 64086  
Permit Number: PRCOM 2021133

Dear Mr. Popp:

The wood blocking is not required to be fire treated in a V-B building.

The Wall Type 01 detail shown on page G02 noted 16" o.c. horizontal stud spacing for vertically installed studs. This portion of the detail was mislabeled "Base Detail" and should read "Plan Detail". Thus, the walls as built do not require horizontal studs.

X   
\_\_\_\_\_  
Logan Hayes  
Architect

[hivekc.com](http://hivekc.com)

1617 WALNUT ST.  
KANSAS CITY, MO  
64108

HIVE Design Collaborative Inc.

Cc: File