

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193622
Address: 1824 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, July 01, 2020

Informational:

1	Misc	- Inspected garage portal -
---	------	-----------------------------

Corrective Action Required:

2	Miscellaneous Correction	**OK TO INSULATE EXCEPT WHERE CORRECTIONS ARE NEEDED. DO NOT SHEET ROCK**
---	--------------------------	----------------------------------------------------------------------------------

-Fire block beam webs-wall by furnace and north mechanical room off of stairs

-Tighten anchor bolts in basement-south wall by closet door and north bedroom

Comments: