

DEVELOPMENT SERVICES

Residential Plan Review

July 01, 2020

SUMMIT HOMES 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

Permit No: PRRES20201756

Plan Name: 1521 SW SUGAR TREE DR.

Project Address: 1521 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

Parcel Number: 69620100600000000

Location: HAWTHORN RIDGE 1ST PLAT, LOTS 1 THRU 100, INCLUSIVE AND TRACTS A, B, C, D & E---LOT 22

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - UNFINISHED BASEMENT - ROOF TRUSS

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Dylan Eppert Rejected

- 1. Drainage swales (where required); show spot elevations within the swale as required to conform to the approved master drainage plan (if applicable), must be provide
- 2. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.

Residential Plan Review Reviewed By: Dylan Eppert Approved

Planning Review (RES) Reviewed By: Shannon McGuire Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:		
Residential, Living Area	1642	
Residential, Un-Finished basements	1527	
Residential, garage	713	

Residential, Living Area 2		785	
Roofing Material		Number of Bathrooms	3.5
Number of Bedrooms	4	Number of Stories	2
Number of Living Units	1	Total Living Area	2427
Sewer Connection Fee	19		