

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193669
Address: 1716 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, July 01, 2020

Corrective Action Required:

1	Miscellaneous Correction	*DO NOT SHEET ROCK** -MAINTAIN GRAVEL FILTER AND SILT FENCE -FIRE STOP CHIMNEY -NAIL SHEATHING PER PLANS THROUGHOUT EXTERIOR -PROVIDE BLOCKING ABOVE WALL AT CANTILEVERS -INSTALL STRINGER CONNECTIONS AND THRUST BLOCKS PER PLANS ON STAIRS
---	--------------------------	--

Comments: