

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20201058  
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Fire Line Construction Inspection</b>	John Jackson	Partial	Wednesday, July 01, 2020

Informational:  
1 Misc 6-30-20 Contractor began to install the fire line approximately Siamese 6" twin fire lines coming from the north in of the building 90 degree bends on both lines. Approximately 100' of 6" Fire Line was layed.

**Comments:**