

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 64081
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	Ronald Paynter	Partial	Wednesday, July 01, 2020

Informational:

1 Misc

Ben's crew from Larry Bair connected the fire line to exterior of the building and poured kickers at the bends. They also set the backflow vault on the slab they poured last week. They have the backflow preventer set in place, but not hooked up yet. RP 7-1-20

Comments: