CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200275 Address: 4400 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, July 02, 2020
Corrective Action Required: 1 Misc	- Provide PFH portal framing per plans		

- EC#2 800 lb hold downs per plans - missing nut on hold down

- Address cut floor joist for DWV basement above egress window - engineer

report needed, header for floor joist bearing on interior framing

- City approved plans show fireplace on cantilever in living room with doubled floor joists above rec room

Comments: