

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192818
Address: 4064 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, July 02, 2020

Corrective Action Required:

1	Misc	-Exterior wall on the north side is less than ten ft from the house to the north and is required to have 1-hr fire rating with exposure on both sides **Inspect later as approved by CMR -Tempered glass window required where within 2 ft of master bedroom exterior **Check later -Fb wall space at basement wet bar from ceiling space (fb top) **Use fiberglass to fb the holes. Take pictures **OK TO INSULATE/ROCK IF THE FIREBLOCKING IS DONE
---	------	--

Comments: