

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20201458  
**Address:** 4412 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Patrick Schonfeldt	Failed - Stop Work	Thursday, July 02, 2020

Corrective Action Required  
1 Misc

- Footing poured without inspection. If 3rd party inspection report must be submitted within 48 hours of inspection. Foundation walls have been poured and forms removed. Stop work order Issued

**Comments:**